

TEST REPORT



REPORT NUMBER: 102808060COQ-001A
ORIGINAL ISSUE DATE: March 24, 2017
REVISION DATE: August 11, 2017

EVALUATION CENTER
Intertek Testing Services NA Ltd.
1500 Brigantine Drive
Coquitlam, BC V3K 7C1
Canada

RENDERED TO

WESTECK WINDOWS MFG.
8104 EVANS ROAD
CHILLIWACK, BC V2R 5R8
CANADA

Product Manufacturer: **Westeck Windows Mfg.**
Product Type: **Vinyl Sliding Door (XO)**
Product Series: **Grandview Series**
Specification: **AAMA/WDMA/CSA 101/I.S.2/A440-08**
AAMA/WDMA/CSA 101/I.S.2/A440-11
A440S1-09
Primary Designator: **Class CW – PG30 – Size Tested 2420 x 2420 mm (95 x 95 in) –**
Type SD
Secondary Designator: **Positive Design Pressure = 1440 Pa (30.1 psf)**
Negative Design Pressure = 1440 Pa (30.1 psf)
Water Penetration Resistance = 360 Pa (7.5 psf)
Canadian Air Leakage Resistance = A3
Test Completion Date: **February 10, 2017**

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to copy or distribute this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

TEST REPORT



REPORT NUMBER: 102741376COQ-001A
ORIGINAL ISSUE DATE: April 4, 2017
REVISION DATE: August 3, 2017

EVALUATION CENTER
Intertek Testing Services NA Ltd.
1500 Brigantine Drive
Coquitlam, BC V3K 7C1
Canada

RENDERED TO

WESTECK WINDOWS MFG.
8104 EVANS ROAD
CHILLIWACK, BC V2R 5R8
CANADA

Product Manufacturer: **Westeck Windows Mfg.**

Product Type: **Vinyl Sliding Door (OXXO)**

Installation Detail: **Nailing flange**

Product Series: **Grandview Series**

Specification: **AAMA/WDMA/CSA 101/I.S.2/A440-08
AAMA/WDMA/CSA 101/I.S.2/A440-11
A440S1-09**

Primary Designator: **Class CW – PG25 – Size Tested 4865 x 2416 mm (192 x 95 in)
– Type SD**

Secondary Designator: **Positive Design Pressure = 1200 Pa (25.1 psf)
Negative Design Pressure = 1200 Pa (25.1 psf)
Water Penetration Resistance = 290 Pa (6.1 psf)
Canadian Air Leakage Resistance = A3**

Test Completion Date: **March 20, 2017**

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to copy or distribute this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

TEST REPORT

Intertek

REPORT NUMBER: 102741376COQ-001B
ORIGINAL ISSUE DATE: April 4, 2017
REVISION DATE: August 3, 2017

EVALUATION CENTER
Intertek Testing Services NA Ltd.
1500 Brigantine Drive
Coquitlam, BC V3K 7C1
Canada

RENDERED TO

WESTECK WINDOWS MFG.
8104 EVANS ROAD
CHILLIWACK, BC V2R 5R8
CANADA

Product Manufacturer: **Westeck Windows Mfg.**

Product Type: **Vinyl Sliding Door (OXXO)**

Installation Detail: **Nailing flange & Interior angle**

Product Series: **Grandview Series**

Specification: **AAMA/WDMA/CSA 101/I.S.2/A440-08
AAMA/WDMA/CSA 101/I.S.2/A440-11
A440S1-09**

Primary Designator: **Class CW – PG35 – Size Tested 4865 x 2416 mm (192 x 95 in)
– Type SD**

Secondary Designator: **Positive Design Pressure = 1680 Pa (35.1 psf)
Negative Design Pressure = 1680 Pa (35.1 psf)
Water Penetration Resistance = 290 Pa (6.1 psf)
Canadian Air Leakage Resistance = A3**

Test Completion Date: **March 20, 2017**

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to copy or distribute this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.