

# WESTECK WINDOWS MFG LTD.

## TEST REPORT

**TEST REPORT ISSUED TO**

Westeck Windows Mfg. Inc.  
8104 Evans Road  
Chilliwack, BC V2R 5R8  
Canada

**SPECIFICATION**

AAMA/WDMA/CSA 101/I.S.2/A440-08  
AAMA/WDMA/CSA 101/I.S.2/A440-11  
A440S1-09, A440S1-17

**PRODUCT SERIES & TYPE**

420.420 Series XO Lift & Slide Sliding Door

**PRIMARY DESIGNATION**

Class LC – PG40 – Size Tested 3962 x 2743 mm (156 x 108 in) – Type SD

**SECONDARY DESIGNATION**

Positive Design Pressure = 1920 Pa (40.1 psf)  
Negative Design Pressure = 1920 Pa (40.1 psf)  
Water Penetration Resistance = 400 Pa (8.4 psf)  
Canadian Air Leakage Resistance= A3

**REPORT NUMBER**

103513395COQ-001B

**ISSUE DATE**

21-May-2019

**PAGES**

59

**DOCUMENT CONTROL NUMBER**

GFT-OP-10b (13-March-2017)  
© 2017 INTERTEK



## TEST REPORT FOR WESTECK WINDOWS MFG. LTD.


Report No.: 103513395COQ-001B


Date: 21-May-2019

### CONCLUSION

The 420.420 Series XO Lift & Slide Sliding Door System, submitted by Westeck Windows Mfg. Ltd., tested and described within this report, achieved the overall performance requirements of **Class LC – PG40** when tested in accordance with NAFS-08, NAFS-11, A440S1-09 and A440S1-17.

For INTERTEK B&C:

<b>COMPLETED BY:</b>	Jason Komorski
<b>TITLE:</b>	Technician – Building & Construction
<b>SIGNATURE:</b>	
<b>DATE:</b>	05/21/19

<b>REVIEWED BY:</b>	David Park
<b>TITLE:</b>	Reviewer – Building & Construction
<b>SIGNATURE:</b>	
<b>DATE:</b>	05/21/19

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to copy or distribute Intertek's Reports and then only in their entirety, and the Client shall not use the Reports in a misleading manner. In the event any portion of this report becomes public, including but not limited to press releases, articles, and marketing material, without prior written consent from Intertek, Intertek may enforce the reproduction of the report in its entirety by making the full report public. Client further agrees and understands that reliance upon the Reports is limited to the representations made therein. In the event any portion of this report becomes public, including but not limited to press releases, articles, and marketing material, without prior written consent from Intertek, Intertek will enforce the reproduction of the report in its entirety by making the full report public. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. Should Customer use an Intertek Report, in whole or in part, in such a manner as to involve Intertek in legal controversy or to adversely affect Intertek's reputation, it shall be Intertek's right to utilize any and all Customer information, including, but not limited to, data, records, instructions, notations, samples or documents within Intertek's custody and control which relate to the customer for the purpose of offering any necessary defense or rebuttal to such circumstances. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.